

**ELECTRIC
MOBILITY
FORUM**

ENGAGE
Connecting Big Ideas To Action

Impact of Electric Vehicle (EV) Charging on the Local Grid

September 16, 2019 | 3:00 PM - 4:00 PM (IST)

 **WRI INDIA**
— ROSS CENTER

 **SHAKTI**
SUSTAINABLE ENERGY
FOUNDATION

Speakers

Dr. Indradip Mitra
Senior Technical Advisor
GIZ GmbH

Sudhanshu Mishra
Technical Expert/Advisor
GIZ

Dr. Chandrasekhar Reddy Atla
Principal Engineer
PRDC

Moderator

Shravani
Sharma
WRI India

Electric Vehicle Charging Technologies

Table: Characteristics of charging levels as defined by the SAE and charging modes as defined by the IEC


Charging level	Voltage	Charging mode	Typical power	Location
Level 1	120 V AC	-	1.2-1.8 kW AC	Primarily residential in North America
Level 2	200-240 V AC	Mode 1	3.6-11 kW AC	Wall socket in Europe; Primarily for 2 & 3 Wheelers
		Mode 2	3.6-22 kW AC	Home and workplace with cable or basic station
		Mode 3	3.6-22 kW AC	Home, workplace and public with hardwired station
Fast Charging	400-1000 V DC	Mode 4	50 kW or more	Public, frequently intercity

Notes: V=Volts; AC= alternating current; DC= direct current; kW=kilowatt


Mitigation of Impacts of Electric Vehicle Charging

The smart charging strategy

Uncontrolled charging



Smart charging



— Demand — Demand with EVs ILLUSTRATIVE

Ref: Tom Buck, e-Mobility The charging infrastructure landscape, a UKEVSE perspective

Simulation Methodology – Data collection, feeder selection criteria

12 Feeders shortlisted by BYPL before the site visit by project team

Arya samaj road nalha

DDA flats pocket B

DSR Mill

E block Vikas Marg

Janta Colony

Karkardoma Court

Karol Bagh - 2

Parade ground

District Center EROS Hotel

Vikas Bhawan

IHBAS Mental hospital

Marjinal Bandh

Criteria For Selection Of Feeders

EV charging stations already exist in the feeder

Solar roof top penetration

Loading of the feeder

Priority for Level 2 chargers and DC Fast Charging

DT loading in the feeder


Voltage profile of the feeder

Consumer mix in the feeder

Monthly energy consumption in the feeder

Simulation Methodology – Data collection, feeder selection criteria

Data Collected



Simulation Studies for Sample Feeders




LEGEND	PARTICULARS	SYMBOL
	33 kV BUS	■
	11 kV BUS	■
	0.415 kV BUS	■
	11 kV CABLE	—
	0.415 kV CABLE	—
	VOLTAGE	in PU


DESCRIPTION	
SHANU SRINIVASU Dr. CS ATLA	DRAWN
Dr. CS ATLA	REVIEWED
Dr. CS ATLA	APPROVED
RO	REV.
19.01.2019	DATE

 <p>PRDC® Power Research and Development Consultants PVT. Ltd., # 5, 11th cross, 2nd stage, West of Chord Road, Bangalore-560 096 Tel:-91-80-4245 5555, 2319 2209 Email: info@prdcinfotech.com</p>	<p>DWG. NO. : JANTACOLONY</p>
---	-------------------------------

Simulation Study: Modeling




Simulation Studies for Sample Feeders



EV Modeling– MiPower Model

Simulation Studies for Sample Feeders



Charger locations





Table 8.1.10: % EV sales assumed for each vehicle category for future years

Vehicle category	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
2W	1%*	3%	5%	10%	15%	25%	27%	30%	33%	35%	37%	40%	40%
3W - PV	5%	10%	15%	20%	25%	25%	30%	40%	50%	60%	70%	80%	100%
3W - CV	0%	3%	5%	10%	15%	25%	30%	35%	40%	45%	50%	60%	70%
4W - PV	1%	1%	5%	10%	15%	25%	25%	25%	26%	27%	28%	29%	30%
4W - CV	1%	5%	10%	15%	20%	25%	30%	40%	50%	60%	70%	80%	100%
Bus	0%	5%	10%	15%	20%	50%	55%	60%	65%	70%	80%	90%	100%

*1% of all 2W sales in 2018 are considered as 2W EV, similarly for all vehicle categories for future years

As per Niti Ayog and Gol targets


Simulation Studies for Sample Feeders



Case Studies Simulated for Selected
Feeders for Future Years


Simulation Studies for Sample Feeders

Projected EV's




Simulation Results – Sample Feeders


Typical day Feeder Load Profile



TRF-2:R.K.DASS-1/2 K. BAGH- LT bus (415 V)




Simulation Results – Sample Feeders



Vehicle Category	Battery Capacity (kWh)	No. of charges per year per vehicle (with SoC of 25%)
2W	4	65
3W - PV	7	487
3W - CV	9	389
4W - PV	80	48
4W - CV	80	292
Bus	250	389




Simulation Results – Sample Feeders




← Feeder Load Profile with EV load

Feeder Load Profile with EV and solar penetration →





Simulation Results – Sample Feeders


Name of the DT	No of EV's charged with public charging	Cumulative battery capacity (kWh)
DT-Public Charging (Capacity: 800 kVA)	96	2167



Simulation Results – Sample Feeders



Simulation Results – Sample Feeders



Conclusions & Recommendation

Extrapolation of the Results to the Entire DISCOM for the Year 2030

Energy and Peak demand requirement for EV charging for the year 2030

EV type	Battery Capacity	EV charging Energy per charge in kWh	No of EVs	No of Charges per EV per year	EV charging Energy in MU
2W	4	3	509281	65	99
3W - PV	7	5.25	93083	594	290
3W - CV	9	6.75	6571	441	20
4W - PV	80	60	182467	48	526
4W - CV	80	60	18478	292	324
Bus	250	187.5	3547	389	259
Total					1517 MU



Conclusions & Recommendation

Summary Of EV Penetration Impact DISCOM system

Projected Energy requirement for year 2019-20 without losses, projected by DISCOM	6925 MU
Energy projection by 2030 without EV and without losses considering growth rate of 4.76%	11022 MU
Projected Peak demand for the year 2019-20 by DISCOM	1640 MW
Projected Peak demand for the year 2029-30 by CAGR of 6% as per historical growth without EVs	2943 MW
Additional energy requirement with EV penetration for the year 2030	1517 MU
% Energy consumption by EV for the year 2030 with reference to energy sales without EVs	13.8%
Energy requirement of DISCOM with EV penetration for the year 2030	12539 MU
Peak demand contribution of EVs as per the DISCOM current load factor of 0.48	361 MW
% peak demand consumption by EV for the year 2030 with reference to peak demand without EVs in the system	12.3%



Conclusions & Recommendation

From the simulations, **peak load** coming from EV charging may not pose a significant toll on the existing business-as-usual infrastructure upgradation plan.

As per the EV projections and EV charging patterns presented in the methodology, un-controlled EV charging will contribute around 13.8% of energy sales for the year 2030.

Similarly, un-controlled EV charging will contribute around 12.3% of peak demand for the year 2030

it is recommended to adopt controlled charging and/or Time of day or Time of Usage tariff to minimize the impact on peak load. This will minimize the grid infrastructure cost considerably.

The impact of EVs on local grid needs to be studied for each system considering the existing infrastructure loading, load profile and solar roof-top PV generation and expected EV profile.





Thank you